

August 14, 2025

Re: Midgard -Spring Lake
14396 NC-210
Spring Lake, NC 28390
BWA # 2023-0683

To whom it may concern:

This letter serves to confirm that, per the owner's direction, the traditional split system shown on the permit documents has been replaced with a wall-mounted split system. We find this alternate installation acceptable, provided the owner has made the appropriate provisions to deliver the minimum code-required outside air to the office spaces.

If you have any questions or comments, please contact me at jcrawford@barrettwoodyard.com or (678) 301-2250.

Sincerely,



Joseph Crawford, P.E.
Barrett, Woodyard, and Associates