



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

9/23/2025

SUBJECT: **MCOM2412-0001**
MECHANICAL COMMERCIAL

To: CERTIFIED HEATING & AIR COND

Here are the results of all Inspections located at **14396 NC 210 S:**

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 1/17/2025
Completed Date/Time: 1/17/2025
Inspector: John B Kokoszka
Result: APPROVED
Remarks:
Notes: Partial for 2nd floor apt.
No duct seal inspection for the living area. Need to remove to see duct seal inspection for inspection or duct blast test

Inspection Type: ROUGH IN
Scheduled Date/Time: 2/19/2025
Completed Date/Time: 2/19/2025
Inspector: James T Hall
Result: APPROVED
Remarks:
Notes: Apartment Only

Inspection Type: ROUGH IN
Scheduled Date/Time: 7/10/2025
Completed Date/Time: 7/10/2025
Inspector: James T Hall
Result: DISAPPROVED
Remarks:
Notes: For rest of building
Need engineer letter for changing AHU on plans to mini split unit in office



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**
Scheduled Date/Time: 8/5/2025
Completed Date/Time: 8/5/2025
Inspector: James T Hall
Result: DISAPPROVED
Remarks:
Notes: Need to label each unit with breakers in electrical panel
Need engineer letter for changing AHU
on plans to mini split unit in office

Inspection Type: FINAL**
Scheduled Date/Time: 8/15/2025
Completed Date/Time: 8/15/2025
Inspector: James T Hall
Result: APPROVED
Remarks:
Notes: engineer letter attached