



# Permit Inspections Harnett County

**Permit Number: MRES1901-0020**

Description: **REPLACE HVAC SYSTEM 2TON**

Applied: **1/17/2019**

Approved: **1/17/2019**

Site Address: **120 CYPRESS CREEK FARM RD**

Issued: **2/27/2019**

Finalized:

City, State Zip Code: **SANFORD, NC 27332**

Status: **ISSUED**

Applicant: **FAYETTEVILLE HEATING & AC CONT**

Parent Permit:

Owner: **HUANTE JOEL**

Parent Project:

Contractor: **FAYETTEVILLE HEATING & AC CONT**

Details:

**Changed electrical contractor on job on 02/27/19. -ad**

## LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FINAL**	Scott Guy		
Notes:						
	1/22/2019	1/22/2019	FINAL**	Scott Guy	FAIL W/ PENALTY	
Notes:						
AM PLEASE Person at location was not notified of an inspection, does no own home, does not what systems were replaced. Contractor must notify customer of the inspection if the contractor calls it in.						
	1/25/2019	1/25/2019	FINAL**	Scott Guy	DISAPPROVED	
Notes:						
AM PLEASE 1- electrical connector at handler box is not proper 2- seal handler a/c line set. 3- verify all breakers and label for location						

