



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

6/11/2021

SUBJECT: MRES2104-0039
MECHANICAL RESIDENTIAL

To: AMI Inc.

Here are the results of all Inspections located at **3143 US 401 S:**

Inspection Type: FINAL**
Scheduled Date/Time: 5/12/2021
Completed Date/Time: 5/12/2021
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks:
Notes: Inspector SPG changed the inspection assignment from SPG to SBL
Need duct blast test on newly installed duct work.

Inspection Type: FINAL**
Scheduled Date/Time: 6/9/2021
Completed Date/Time: 6/9/2021
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes: Inspector SPG changed the inspection assignment from SPG to SBL