

Application # _____

Harnett County Central Permitting

PO Box 65 Lillington, NC 27546 - Ph: 910-893-7525 - Fx: 910-893-2793 - www.harnett.org/permits
Certification of Work Performed By Owner/Contractor
(Individual Trade Application)

Owner (s) of Structure: Alexander & Shari Samms Phone: (910) 433-2724

Owner (s) Mailing Address: 5300 sports club run Suffolk VA 23435

Land Owner Name (s): Alexander & Shari Samms Phone: (910) 433-2724

Construction or Site Address: 42 Walnut Grove Dr. Bunnlevel, NC 28303

PIN # 0525-87-8723.000 Parcel # 010525 006244

Job Cost: \$2,000 Description of Work to be done 2.5 ton heat pump split system changeout

Mechanical: New Unit With Ductwork New Unit Without Ductwork Gas Piping Other

Electrical*: 200 Amp <200 Amp Service Change Service Reconnect Other
* For Progress Energy customers we need the premise number

Plumbing: Water/Sewer Tap Number of Baths Water Heater

Specific Directions to Job from Lillington:

Subdivision: Walnut Grove Lot #: 35

I, James Woody (Contractors Name) will provide the mechanical (Trade) labor on this structure.

I am the building owner or my NC state license number is 30486, which entitles me to perform such work on the above structure legally. All work shall comply with the State Building Code and all other applicable State and local laws, ordinances and regulations.

Premier Heating and Air
Contractor's Company Name

(910) 965-0222
Telephone

581 Executive pl. Suite #300 Fay NC 28305
Address

callpremierheatingandair@gmail.com
Email Address

30486
License #

Structure Owner / Contractor Signature: James Woody Date: 5/10/2021

By signing this application you affirm that you have obtained permission from the above listed license holder to purchase permits on their behalf. If doing the work as owner you understand that you cannot rent, lease or sell the listed property for 12 months after completion of the listed work.

Electrical Contractor

*Company name, address, & phone must match information on license

Flash Gordon Electric Lic # 33679 (910) 583-8441

Doing unhook + rehook for changeout.