



Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

5/26/2023

SUBJECT: MRES2305-0034
MECHANICAL RESIDENTIAL

To: FAYETTEVILLE HEATING & AC CONT

Here are the results of all Inspections located at **31 ESSEX CT E:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 5/24/2023
Completed Date/Time: 5/24/2023
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Need correct size wire and breaker.