



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

11/20/2023

SUBJECT: MRES2305-0034
MECHANICAL RESIDENTIAL

To: FAYETTEVILLE HEATING & AC CONT

Here are the results of all Inspections located at **31 ESSEX CT E:**

Inspection Type: FINAL**
Scheduled Date/Time: 5/24/2023
Completed Date/Time: 5/24/2023
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Need correct size wire and breaker.

Inspection Type: FINAL**
Scheduled Date/Time: 5/31/2023
Completed Date/Time: 5/31/2023
Inspector: James T Hall
Result: DISAPPROVED
Remarks:
Notes: No answer at front door

Inspection Type: FINAL**
Scheduled Date/Time: 6/6/2023
Completed Date/Time: 6/6/2023
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: No answer at door. Crawl unit needs to be rechecked. Owner doesn't need to be home if we have permission to enter backyard.

Inspection Type: FINAL**
Scheduled Date/Time: 7/14/2023
Completed Date/Time: 7/14/2023
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: MCA exceeds 30 amp for #10 romex.



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**
Scheduled Date/Time: 11/17/2023
Completed Date/Time: 11/17/2023
Inspector: John B Kokoszka
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 11/14/2023 8:04 AM FAYETTEVILLE HEATING & AC CONT
PLEASE ARRIVE AFTER 3PM!!
Contact Name: FAYETTEVILLE HEATING & AC CONT
Site Address: 31 ESSEX CT E
Phone: 9104842273
e-Mail: fayheatair@yahoo.com