



Permit Inspections Harnett County

Permit Number: **MRES2311-0011**

Description: **16x23 Sunroom**

Applied: **11/13/2023**

Approved: **11/13/2023**

Site Address: **485 TYLERSTONE DR**

Issued: **11/14/2023**

Finalized: **4/8/2024**

City, State Zip Code: **FUQUAY-VARINA, NC 27526**

Status: **ISSUED**

Applicant: **RODAS CRONSTRUCTION**

Parent Permit: **BRES2309-0011**

Owner: **MILLER LARRY**

Parent Project:

Contractor: **RODAS CRONSTRUCTION**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	3/19/2024	3/19/2024	ROUGH IN	Brad Sutton	APPROVED W/EXC	
Notes: Mechanical supply for sunroom shall be zoned separate from the house per energy code. Must have its own thermostat, and remain thermally isolated from the remainder of the house. Existing exterior door must remain in place						
	4/8/2024	4/8/2024	FINAL**	Justin Ryan McLeod	APPROVED	
Notes:						
	4/11/2024	4/11/2024	ROUGH IN REINSPECT	Justin Ryan McLeod	APPROVED	
Notes:						

