



**Harnett County**  
 420 McKinney Pkwy  
 LILLINGTON, NC 27546  
 Phone:  
 Fax:

8/19/2024

**SUBJECT: MRES2401-0020  
 MECHANICAL RESIDENTIAL**

To: TACIA CHARLES C III

Here are the results of all Inspections located at **748 SPRING HILL CHURCH RD:**

Inspection Type: FINAL\*\*  
 Scheduled Date/Time:  
 Completed Date/Time:  
 Inspector: Steven Gazlay  
 Result:  
 Remarks:  
 Notes:

Inspection Type: ROUGH IN  
 Scheduled Date/Time: 3/12/2024  
 Completed Date/Time: 3/12/2024  
 Inspector: James T Hall  
 Result: APPROVED  
 Remarks:  
 Notes:

Inspection Type: FINAL\*\*  
 Scheduled Date/Time: 7/2/2024  
 Completed Date/Time: 7/2/2024  
 Inspector: John B Kokoszka  
 Result: DISAPPROVED  
 Remarks:  
 Notes: Need to seal kitchen backsplash at sink  
 Need to seal both toilets  
 Need to seal attic access. Need to label interior panel and missing arc faults  
 many wires need to be secured wire in crawl and remove Insulation down in crawl  
 One register is feeding the crawl, not closed off  
 Duck needs to be 4 inches off the ground  
 Lead the label, mechanical unit for breaker sizes  
 Missing duct leakage test

Inspection Type: FINAL\*\*  
 Scheduled Date/Time: 7/17/2024  
 Completed Date/Time: 7/17/2024  
 Inspector: John B Kokoszka  
 Result: DISAPPROVED  
 Remarks:  
 Notes: Inspector SPG changed the inspection assignment from SPG to JBK





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type:        Need to seal attic access. Missing Insulation in a few places in crawl Lead the label, mechanical  
Scheduled Date/Time:    unit for breaker sizes sticker needs to be marked what unit it is  
Completed Date/Time: