



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

8/22/2024

SUBJECT: MRES2401-0020
MECHANICAL RESIDENTIAL

To: TACIA CHARLES C III

Here are the results of all Inspections located at **748 SPRING HILL CHURCH RD:**

Inspection Type: ROUGH IN
Scheduled Date/Time: 3/12/2024
Completed Date/Time: 3/12/2024
Inspector: James T Hall
Result: APPROVED
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 7/2/2024
Completed Date/Time: 7/2/2024
Inspector: John B Kokoszka
Result: DISAPPROVED
Remarks:
Notes:

Need to seal kitchen backsplash at sink
Need to seal both toilets
Need to seal attic access. Need to label interior panel and missing arc faults many wires need to be secured wire in crawl and remove Insulation down in crawl
One register is feeding the crawl, not closed off
Duck needs to be 4 inches off the ground
Lead the label, mechanical unit for breaker sizes
Missing duct leakage test

Inspection Type: FINAL**
Scheduled Date/Time: 7/17/2024
Completed Date/Time: 7/17/2024
Inspector: John B Kokoszka
Result: DISAPPROVED
Remarks:
Notes:

Inspector SPG changed the inspection assignment from SPG to JBK
Need to seal attic access. Missing Insulation in a few places in crawl
Lead the label, mechanical unit for breaker sizes
sticker needs to be marked what unit it is



Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**
Scheduled Date/Time: 8/22/2024
Completed Date/Time: 8/22/2024
Inspector: John B Kokoszka
Result: APPROVED
Remarks:
Notes: after 2 if possible