

2221 S. Horner Blvd. • Sanford, NC 27330 • 919-775-3013

The gas line at 275 Lakeland Port, Permit #MRES2409-0015, has been installed to code. The gas line is at a depth of 16 inches and also sleeved where the concrete will be poured.

Thank you,

Jamie Harbin

Service Manager.