



Permit Inspections

Harnett County

Permit Number: MRES2509-0007

Description: **hvac replacement**

Applied: **9/4/2025**

Approved: **9/4/2025**

Site Address: **1160 JOEL JOHNSON RD**

Issued: **9/9/2025**

Finalized: **9/16/2025**

City, State Zip Code: **LILLINGTON, NC 27546**

Status: **FINALED**

Applicant: **Innovative Builds, Inc.**

Parent Permit:

Owner: **RAY PAUL**

Parent Project:

Contractor: **Innovative Builds, Inc.**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FINAL**	Steven Gazlay		
Notes:						
			FINAL**	Steven Gazlay		eTRAKiT Inspection Request
Notes:						
	9/15/2025	9/15/2025	FINAL**	John B Kokoszka	DISAPPROVED	eTRAKiT Inspection Request
Notes: 9/10/2025 5:38 PM Thea Comoda Contact Name: Thea Comoda Site Address: 1160 JOEL JOHNSON RD Phone: 9107781976 e-Mail: thea@maybridgere.com Need to label heat strips fir max over current device						
	9/16/2025	9/16/2025	FINAL**	James T Hall	APPROVED	eTRAKiT Inspection Request
Notes: 9/15/2025 12:43 PM Thea Comoda Contact Name: Thea Comoda Site Address: 1160 JOEL JOHNSON RD Phone: 9107781976 e-Mail: thea@maybridgere.com						