

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		G-7	G-21	G-18											
Texture Group	.1941(A)(1)	Fill	Fill	Fill											
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 2 DEPTH		7-21	21-38	18-20											
Texture Group	.1941(A)(1)	SL	SL	SL											
Consistence	.1941	VFr	Fr	VFr											
Structure	.1941(A)(2)	C	SBK	C											
Mineralogy	.1941(A)(3)	NCH	SEXP	UExp											
HORIZON 3 DEPTH		21-38		20-26											
Texture Group	.1941(A)(1)	C		C											
Consistence	.1941	Fi		Fi											
Structure	.1941(A)(2)	SBK		SBK											
Mineralogy	.1941(A)(3)	SEXP		SEXP											
HORIZON 4 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
SOIL WETNESS	.1942														
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/.1956														
CLASSIFICATION	.1948	PS	PS	PS											
LONG TERM ACCEPTANCE RATE	.1955	.3	.3	.3											

red



(3)

(2)