



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

12/4/2018

SUBJECT: PCOM1810-0006
PLUMBING COMMERCIAL

To: MLS PLUMBING CO INC

Here are the results of all Inspections located at **169 HIGHGROVE DR T:**

Inspection Type: FINAL**
Scheduled Date/Time: 11/19/2018
Completed Date/Time: 11/19/2018
Inspector: Jimmy Hall
Result: DISAPPROVED
Remarks:
Notes: water tap connection
Need cutoff 12" or less from meter and need to see water line for inspection

Inspection Type: FINAL**
Scheduled Date/Time: 12/3/2018
Completed Date/Time: 12/3/2018
Inspector: Jimmy Hall
Result: APPROVED
Remarks:
Notes: