Gerald P. Noe, Architect



John Ray CECG, LLC Capital Empire Construction Group, LLC 135 Parkway Office Ct.-Suite 201 Cary, NC 27518

Ref: Marcos Pizza - Sanford, N. Carolina

Mr. Ray,

The purpose of this letter is to acknowledge that the floor drain shown beside the walk-in on the AP-1 sheet of our construction documents is not needed. This unit is self-contained, the floor drain does not need to be installed in this location.

The waste line has also been reduced to a maximum of 3" since the existing sewer connection for this space is a 3" service line.

If there are any questions or concerns, please feel free to contact me.

Respectfully Submitted,

