



Harnett County Fire Marshals Office

Occupancy: **The Springs of Ballentine**

Occupancy ID: **4300SENT000001**

Address: **40 RAWLS CLUB RD FUQUAY VARINA NC 27526**

Inspection Type: **303.5 - Underground Piping, Thrust Block Insp.**

Inspection Date: **8/15/2023** By: **SULLIVAN, ROGER (2312)**

Time In: **10:00** Time Out: **11:30**

Authorized Date: **08/15/2023** By: **SULLIVAN, ROGER (2312)**

Next Inspection Date: **No Inspection Scheduled**

Form: Harnett County
General Fire Inspection

Inspection Description:

Harnett County Fire Inspection

Inspection Topics:

Fire Protection Systems

Fire Suppression Systems
Installed, Tested, and Maintained

Status: PASS

Notes: Thrust block inspection for fire department connection piping, checked two pipe bends, no issues noted.

Statement of Compliance

An inspection of your facility on this date revealed no violations of the North Carolina State Fire Prevention Code. No further inspections will need to be conducted until your next regular schedule fire inspection.

Statement of Compliance

Status: PASS

Notes:

Additional Time Spent on Inspection:

Category	Start Date / Time	End Date / Time
----------	-------------------	-----------------

Notes: No Additional time recorded

Total Additional Time: 0 minutes

Inspection Time: 90 minutes

Total Time: 90 minutes

Summary:

Overall Result: Fire Code Compliance

An inspection of your facility revealed no violations of the North Carolina Fire Code.

Inspector Notes:

Closing Notes:

Harnett County has adopted The Compliance Engine as the prescribed method for record keeping in accordance with Section 107, of the North Carolina Fire Prevention Code. Records of periodic inspections, tests, servicing, and other operations and maintenance for all life safety systems shall be submitted to The Compliance Engine.

Inspector:

Name: SULLIVAN, ROGER
Rank: Deputy Fire Marshal
Work Phone(s): None on file
Email(s): rsullivan@harnett.org

Signature

Date

Representative Signature:

Signature

Date