



Permit Inspections Harnett County

Permit Number: PCOM2308-0002

Description: Amenity Center w/2 bathrooms and equipment

Applied: **8/2/2023**

Approved: **8/2/2023**

Site Address: **196 PROVIDENCE CREEK DR**

Issued: **9/1/2023**

Finalized:

City, State Zip Code: **FUQUAY-VARINA, NC 27526**

Status: **ISSUED**

Applicant: **Mattamy Homes LLC**

Parent Permit: **BCOM2201-0003**

Owner: **MATTAMY HOMES LLC**

Parent Project:

Contractor: **Poythress Commercial Contractors, Inc.**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			SEWER CONNECTION	Justin Ryan McLeod		
Notes:						
			WATER CONNECTION	Justin Ryan McLeod		
Notes:						
			FINAL**	Justin Ryan McLeod		
Notes:						
	11/30/2023	11/30/2023	UNDER SLAB	Daniel L Floyd	DISAPPROVED	
Notes: under slab plumbing Drain lines are not as plans show, need an engineers letter						
	12/28/2023	12/28/2023	UNDER SLAB	Justin Ryan McLeod	APPROVED	
Notes: Letter for drain line per last inspection.						
	2/1/2024	2/1/2024	SEWER CONNECTION	Daniel L Floyd	APPROVED W/EXC	
Notes: Still need to see connection at building but from road to building is good to cover up.						
	2/1/2024	2/1/2024	UNDER SLAB	Daniel L Floyd	CANCELLED	
Notes: Contractor didn't know why this was scheduled						
	2/1/2024	2/1/2024	SEWER CONNECTION	Daniel L Floyd	APPROVED	
Notes:						





Permit Inspections

Harnett County

	2/1/2024	2/1/2024	WATER CONNECTION	Daniel L Floyd	APPROVED	
Notes:						
	4/18/2024	4/18/2024	UNDER SLAB	Justin Ryan McLeod	APPROVED	
Notes:						
	6/7/2024	6/7/2024	ROUGH IN	Justin Ryan McLeod	APPROVED	
Notes: Plumber onsite was finishing the drain test when arrived, waited the time per code for the test, which was good.						

