



# Permit Inspections Harnett County

**Permit Number: PRES1911-0011**

Description: **Redo electrical / replace tub**

Applied: **11/22/2019**

Approved: **11/22/2019**

Site Address: **100 PINECREST ST B**

Issued: **11/22/2019**

Finalized: **4/1/2020**

City, State Zip Code: **SPRING LAKE, NC 28390**

Status: **FINALED**

Applicant: **NORTHPOINT LAKE CHARLES LLC**

Parent Permit: **ERES1911-0036**

Owner: **NORTHPOINT LAKE CHARLES LLC**

Parent Project:

Contractor: **Anderson's Electrical**

Details:

### LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ROUGH IN	Slade Burton Lawson III		
Notes:						
	11/25/2019	11/25/2019	ROUGH IN	Steven Gazlay	DISAPPROVED	
Notes: Inspector SBL changed the inspection assignment from SBL to SPG Washer box not installed, pressure test down. Seal around drain pipe for tube. Tub test not ready. Fire caulk top plate penetrations. Need permits for all trades and firewalls. Mechanical, building, insulation, electrical and plumbing. Need licensed contractors listed on permits.						
	12/5/2019	12/5/2019	ROUGH IN	Steven Gazlay	CANCELLED	
Notes: Inspector SBL changed the inspection assignment from SBL to SPG						
	12/9/2019	12/9/2019	ROUGH IN	Slade Burton Lawson III	DISAPPROVED	
Notes: Seal around bath tub drain.						
	12/9/2019	12/10/2019	ROUGH IN	Slade Burton Lawson III	CANCELLED	
Notes:						
	12/17/2019	12/17/2019	ROUGH IN	Slade Burton Lawson III	APPROVED	
Notes: sbl changed Inspection Date/Time from 12/16/2019 to 12/17/2019						
	3/24/2020	3/24/2020	FINAL**	Slade Burton Lawson III	DISAPPROVED	
Notes: Drain line for dishwasher not installed per code						





# Permit Inspections Harnett County

	3/27/2020	3/27/2020	FINAL**	Slade Burton Lawson III	DISAPPROVED	
Notes: See BRES						
	4/1/2020	4/1/2020	FINAL**	Slade Burton Lawson III	APPROVED	
Notes:						

