



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

9/7/2022

**SUBJECT: PRES2207-0029
PLUMBING RESIDENTIAL**

To: HOSKINS ANGELIQUE JANNA

Here are the results of all Inspections located at **12 BALLENTYNE CT:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 8/29/2022
Completed Date/Time: 8/29/2022
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Must have cut off in separate box located 12 inch behind county meter setter.