



**Harnett County**  
420 Mckinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

9/12/2022

**SUBJECT: PRES2207-0029**  
**PLUMBING RESIDENTIAL**

To: HOSKINS ANGELIQUE JANNA

Here are the results of all Inspections located at **12 BALLENTYNE CT:**

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 8/29/2022  
Completed Date/Time: 8/29/2022  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: Must have cut off in separate box located 12 inch behind county meter setter.

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 9/9/2022  
Completed Date/Time: 9/9/2022  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes: