



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

2/7/2023

**SUBJECT: PRES2301-0016
PLUMBING RESIDENTIAL**

To: YOUNG ALEXANDRIA ORRORA

Here are the results of all Inspections located at **25351 NC 24-27:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 2/7/2023
Completed Date/Time: 2/7/2023
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes:

Insulate expansion tank and exposed water lines under home. Support piping every 4 foot.
Foam holes in floor penetrations. Nail or use structural screws and secure blocking for shower
head dog ear fitting. Secure dog ear fittings.

