



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

6/9/2023

**SUBJECT: PRES2302-0016
PLUMBING RESIDENTIAL**

To: STAVRINOS PHILIP

Here are the results of all Inspections located at **198 FLETCHER TUTOR RD:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 6/7/2023
Completed Date/Time: 6/7/2023
Inspector: Justin Ryan McLeod
Result: APPROVED W/EXC
Remarks: eTRAKiT Inspection Request
Notes: 6/5/2023 12:58 PM Nathan Benson

Contact Name: Nathan Benson
Site Address: 198 FLETCHER TUTOR RD
Phone: 9196248943
e-Mail: nate.benson123@gmail.com

Will have to insulate lines and p trap under floor before final