



**Harnett County**  
420 Mckinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

11/15/2023

**SUBJECT: PRES2310-0014**  
**PLUMBING RESIDENTIAL**

To: PIPEWORX PLUMBING

Here are the results of all Inspections located at **170 WATERS WAY:**

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 11/13/2023  
Completed Date/Time: 11/13/2023  
Inspector: John B Kokoszka  
Result: DISAPPROVED  
Remarks:  
Notes:

Inspector JTH changed the inspection assignment from JTH to JBK  
Missing cutoff within 12" from meter. Across from address sign the water service is not 12" below grade.