



Permit Inspections Harnett County

Permit Number: PRES2404-0016

Description: **Remodel of entire home no changes in sq ft**

Applied: **4/18/2024**

Approved: **4/18/2024**

Site Address: **608 N 15TH ST**

Issued: **4/18/2024**

Finaled: **5/23/2024**

City, State Zip Code: **ERWIN, NC 28339**

Status: **FINALED**

Applicant: **Tommy Core's Residential Construction LLC**

Parent Permit: **BRES2404-0067**

Owner: **FLIPS FOR HUMANITY LLC**

Parent Project:

Contractor: **Tommy Core's Residential Construction LLC**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ROUGH IN REINSPECT	Deen Taylor		
Notes:						
	4/26/2024	4/26/2024	ROUGH IN	Deen Taylor	DISAPPROVED	
Notes: Washing machine drain box must be minimum 34 inches above finished walking surface. Currently 31 inches above rough walking surface. Frame around and fire block, top of plumbing pipe and left bedroom closet.						
	5/21/2024	5/23/2024	FINAL**	Deen Taylor	APPROVED	
Notes:						

