



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

10/3/2025

SUBJECT: **PRES2508-0023**  
**PLUMBING RESIDENTIAL**

To: GEDDES BRIAN

Here are the results of all Inspections located at **2817 CAROLINA WAY:**

Inspection Type: ROUGH IN  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: ROUGH IN  
Scheduled Date/Time: 8/25/2025  
Completed Date/Time: 8/25/2025  
Inspector: Ricardo D Honrada  
Result: DISAPPROVED  
Remarks:  
Notes: Sewer and water pipes have been relocated, need to water test. Water distribution pipes and sewer pipes need supported as per code.

Inspection Type: ROUGH IN  
Scheduled Date/Time: 8/29/2025  
Completed Date/Time: 8/29/2025  
Inspector: Ricardo D Honrada  
Result: DISAPPROVED  
Remarks:  
Notes: Need to fixed the cable under the house where it loop



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ROUGH IN

Scheduled Date/Time: 10/3/2025

Completed Date/Time: 10/3/2025

Inspector: Ricardo D Honrada

Result: FAIL W/ PENALTY

Remarks:

Notes:

Inspector JTH changed the inspection assignment from JTH to RH

Dishwasher drain no air gap. Pipe penetration through the floor next to water closet needs to seal. Lavatory stand base needs to seal.

Inspection Type: FINAL \*\*

Scheduled Date/Time: 10/3/2025

Completed Date/Time: 10/3/2025

Inspector: Ricardo D Honrada

Result: DISAPPROVED

Remarks:

Notes:

Inspector JTH changed the inspection assignment from JTH to RH

Pass the rough in inspection.