



Permit Inspections

Harnett County

Permit Number: PRES2508-0023

Description: 1st floor and kitchen renovation from fire

Applied: 8/22/2025

Approved: 8/22/2025

Site Address: 2817 CAROLINA WAY

Issued: 8/22/2025

Finalized:

City, State Zip Code: SANFORD, NC 27332

Status: ISSUED

Applicant: GEDDES BRIAN

Parent Permit: BRES2508-0032

Owner: GEDDES BRIAN

Parent Project:

Contractor: SHOWCASE RESTORATION NC INC

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ROUGH IN	James T Hall		
Notes:						
			FINAL**	James T Hall		
Notes:						
	8/25/2025	8/25/2025	ROUGH IN	Ricardo D Honrada	DISAPPROVED	
Notes:						
Sewer and water pipes have been relocated, need to water test. Water distribution pipes and sewer pipes need supported as per code.						
	8/29/2025	8/29/2025	ROUGH IN	Ricardo D Honrada	DISAPPROVED	
Notes:						
Need to fixed the cable under the house where it loop						
	10/3/2025	10/3/2025	ROUGH IN	Ricardo D Honrada	FAIL W/ PENALTY	
Notes:						
Inspector JTH changed the inspection assignment from JTH to RH						
Dishwasher drain no air gap. Pipe penetration through the floor next to water closet needs to seal. Lavatory stand base needs to seal.						
	10/3/2025	10/3/2025	FINAL**	Ricardo D Honrada	DISAPPROVED	
Notes:						
Inspector JTH changed the inspection assignment from JTH to RH						
Pass the rough in inspection.						