

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940										
SLOPE (%)	.1940										
HORIZON 1 DEPTH		0-48	0-34	0-30	0-32						
Texture Group	.1941(A)(1)	LS	LS	LS	LS						
Consistence	.1941	VFR	VFR	VFR	VFR						
Structure	.1941(A)(2)	G	G	G	G						
Mineralogy	.1941(A)(3)	NS/NP	NS/NP	NS/NP	NS/NP						
HORIZON 2 DEPTH			34-48	30-28	32 ¹¹						
Texture Group	.1941(A)(1)		SCL	SCL	SCL						
Consistence	.1941		FR	FR	FR						
Structure	.1941(A)(2)		SBK	SBK	SBK						
Mineralogy	.1941(A)(3)		SS/P	SS/SP	SS/SP						
HORIZON 3 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942										
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948	S	PS	PS	PS						
LONG TERM ACCEPTANCE RATE	.1955	.8	.5	.5	.5						

4-80 18-24

④

③

⑤

①

