

03-5-2016

NETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH SECTION

No 15479

# OPERATIONS PERMIT

Name: (owner) James Mark Currie  New Installation  Septic Tank  
 Property Location: SR# 27 West  Repairs  Nitrification Line  
 Subdivision Home Star Est. Lot # 6  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: Hal Brown Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:   
 Water Supply:  Well  Public  Community  
 Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
 Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
 Subsurface Drainage Field No. of ditches 1 exact length 320 width of ditches 3 depth of ditches 18-24 in.  
 French Drain: \_\_\_\_\_ Linear feet

Date: 12/23/2002

PERMIT NO. 19924

Inspected by: Bryon McLean R.S.  
Environmental Health Specialist

