

# SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

FACTORS		PROFILES												
		1	2	3	4	5	6	7	8	9	10			
LANDSCAPE POSITION	.1940													
SLOPE (%)	.1940													
HORIZON 1 DEPTH		0-10	0-12	0-12										
TEXTURE GROUP	.1941(A)(1)	SL	SL	SL										
CONSISTENCE	.1941	VFR	VFR	VFR										
STRUCTURE	.1941(A)(2)	G	G	G										
MINERALOGY	.1941(A)(3)	NS/MP	NS/MP	NS/MP										
HORIZON 2 DEPTH		10-32"	12-38"	12-32"										
TEXTURE GROUP	.1941(A)(1)	SCL	SCL	SCL										
CONSISTENCE	.1941	FR	FR	FR										
STRUCTURE	.1941(A)(2)	SBX	SBX	SBX										
MINERALOGY	.1941(A)(3)	SS/SP	SS/SP	SS/SP										
HORIZON 3 DEPTH														
TEXTURE GROUP	.1941(A)(1)													
CONSISTENCE	.1941													
STRUCTURE	.1941(A)(2)													
MINERALOGY	.1941(A)(3)													
HORIZON 4 DEPTH														
TEXTURE GROUP	.1941(A)(1)													
CONSISTENCE	.1941													
STRUCTURE	.1941(A)(2)													
MINERALOGY	.1941(A)(3)													
SOIL WETNESS	.1942													
RESTRICTIVE HORIZON	.1944													
SAPROLITE	.1943/1956													
CLASSIFICATION	.1948	PS	PS	PS										
LONG TERM ACCEPTANCE RANGE	.1955	.4	.4	.4										

FREE WATER @ 24"

NEED FRENCH DRAIN

