

IMPROVEMENT PERMIT

03-56453

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Robert J. Terry, Jr. New Installation Septic Tank
Property Location: SR# NC24/27 Repairs Nitrification Line

Subdivision The Highlands @ Shallow Ford Lot # 47

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 (30x60) Lot Size: 52 Ac.

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of exact length width of depth of
ditches 1 of each ditch 300 ft. ditches 3 ft. ditches 18 in.

French Drain Required: _____ Linear feet

Date: 02-18-07

This permit is subject to revocation if site plans or intended use change.

Signed: Jon W. ARL
Environmental Health Specialist



STUB out
Plumbing
shallow
where
shown
maintain
All set Back,
Do not
Drive or
Park on septic
SYSTEM

HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT

Permit # 19942

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department, Improvement Permit # 03-5-6453. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Name Robert & Terri Cizei Telephone# 499-2424

Address _____

NC 24/27

Property Location SR# _____ Road Name _____

Subdivision The Highland @ Sherwood Forest Lot # 47 # Bedrooms Proposed 3 (70x60) Lot Size 5212

TYPE OF SYSTEM

New Installation Repair Septic Tank Nitrification Lines
 Conventional Other _____

Basement With Plumbing Without Plumbing

Water Supply: Well Public Water Supply Minimum Well Setback: 50 Ft.

Septic Tank 1000 Pump Chamber _____

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 1 Length of lines 300 Ft.

Width of ditches 3 ft. Depth of ditches 18 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

Signature of Authorized Agent for Harnett County of Harnett [Signature] Date 02-18-03