

OPERATIONS PERMIT

03-5-6646

Name: (owner) Benjamin Zupanic

New Installation Septic Tank

Property Location: SR# 1139

Repairs Nitrification Line

Subdivision _____ Lot # _____

TAX ID# _____ Quadrant # _____

Contractor: LARRY SHARPC

Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 4 exact length 100 ft. width of ditches 3 ft. depth of ditches 18 in.

French Drain: _____ Linear feet

Date: 4-15-03

PERMIT NO. 19276

Inspected by: Joe Waters
Environmental Health Specialist

