

03-5-6854

NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15883

OPERATIONS PERMIT

Name: (owner) RANDY + AMY GRIFFIN New Installation Septic Tank
 Property Location: SR#1141 MICROTOWER RD Repairs Nitrification Line
 Subdivision HIGHLAND HILLS Lot # 12
 TAX ID# _____ Quadrant # _____
 Contractor: OTIS STRICKLAND Registration # _____

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field No. of ditches 3 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 18-24 in.
 French Drain: _____ Linear feet

Date: 5/7/03
 Inspected by: [Signature] Environmental Health Specialist

PERMIT NO. 19250

