

03-57411

HARNETT COUNTY HEALTH DEPARTMENT

No 20096

# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) STAHL, JAMES E.  New Installation  Septic Tank  
Property Location: SR# 1132 LOOP RD  Repairs  Nitrification Line

Subdivision \_\_\_\_\_ Lot # 36

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 4 Lot Size: 24.28 AC

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 5 exact length of each ditch 105 ft. width of ditches 3 ft. depth of ditches \_\_\_\_\_ in.


French Drain Required: \_\_\_\_\_ Linear feet

Date: 7/8/03  
Signed: [Signature] **RS (OLIVER TOLKSDORF)**  
Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

DRAWING  
NTS

- \* MAINTAIN ALL SETBACKS
- \* CALL WITH ANY QUESTIONS PRIOR TO INSTALLATION
- \* SEPTIC TANK MAY BE PLACED BEHIND HOUSE BUT PROPER FALL MUST BE MAINTAINED



SR 1132

HARNETT COUNTY HEALTH DEPARTMENT  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department, Improvement Permit # 20096. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Name STAHL, JAMES E. Telephone# 919-376-0875

Address PO Box 1145 LILLINGTON NC 27546

Property Location SR# 1132 LOOP RD Road Name \_\_\_\_\_

Subdivision \_\_\_\_\_ Lot # 4 # Bedrooms Proposed \_\_\_\_\_ Lot Size 24,28 AC

**TYPE OF SYSTEM**

New Installation [ ] Repair  Septic Tank  Nitrification Lines  
 Conventional [ ] Other \_\_\_\_\_

[ ] Basement [ ] With Plumbing [ ] Without Plumbing

Water Supply:  Well [ ] Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber \_\_\_\_\_ gal

**NITRIFICATION FIELD SPECIFICATIONS**

Number of fields 1 # of lines per field 5 Length of lines 105 Ft.

Width of ditches 3 ft. Depth of ditches 18-20 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

Signature of Authorized Agent for Harnett County of Harnett [Signature] Date 7/8/03