

# SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME \_\_\_\_\_

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-2"	0-6"	0-10"	0-10"										
Texture Group	.1941(A)(1)	SL	SL	SL	SL										
Consistence	.1941	VFR	VFR	VFR	VFR										
Structure	.1941(A)(2)	C	G	G	G										
Mineralogy	.1941(A)(3)	NS/NP	NS/NP	NS/NP	NS/NP										
HORIZON 2 DEPTH		2-42"	6-42"	10"-42"	10"X										
Texture Group	.1941(A)(1)	C	C	C	C										
Consistence	.1941	FR	FR	FR	FR										
Structure	.1941(A)(2)	SBK	SBK	SBK	SBK										
Mineralogy	.1941(A)(3)	S/P	S/P	S/P	S/P										
HORIZON 3 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 4 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
SOIL WETNESS	.1942				36"										
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/.1956														
CLASSIFICATION	.1948	P5	P5	P5	P5										
LONG TERM ACCEPTANCE RATE	.1955	.3	.3	.3	.3										

7x80 @ 18"-24"

SITE PLAN APPROVAL

DISTRICT BA2023 USE DWMMH

#BEDROOMS 4

Date 7-18-03 Zoning Administrator [Signature]

VATER ABUI  
DB. 702, PG. 30

