

Applicant:

Date Evaluated: 12/18/03

Property Size:

Property Recorded:

Address:

Proposed Facility: 2 BDM HOME Design Flow (.1949): 240 gpd

Location of Site:

Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other

Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut

Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

[illegible]

Description	Initial System	Repair System
Available Space (.1945)	↓	✓
System Type(s)	PUMP TO CON.	PUMP TO CON.
Site LTAR	3	3

Other Factors (.1946): _____

Site Classification (.1948): *PS*

Evaluated By: 

Others Present:

COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND		FR-FRIABLE	SS-SLIGHTLY STICKY
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
FS-FOOT SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM			SP-SLIGHTLY STICKY
CC-CONCLAVE SLOPE		CL-CLAY LOAM			P-PLASTIC
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			VP-VERY PLASTIC
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE


SG-SINGLE GRAIN
M-MASSIVE
CR-CRUMB
GR-GRANULAR
SBK-SUBANGULAR BLOCKY
ABK-ANGULAR BLOCKY
PL-PLATY
PR-PRISMATIC

MINERALOGY

SLIGHTLY EXPANSIVE

EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



1=100

PLAN APPROVAL

DISTRICT KAZOR USE DWMH

BEDROOMS 2

12-12-03 J. Johnson

AMBER P. LEE

DB 1519, PG 881

PC F, SLIDE 574-C

DELT WEST

DB 1154, PG 255

PC F, SLIDE 574-C

1.00 AC.

FINISH FLOOR

PROPOSED HOME SITE

EIS

"OUR WAY LANE" 50' R/W
EXISTING EASEMENT AS SHOWN ON MAP NO. 2002-1255

AMBER P. LEE

DB 1519, PG 881

THIRD PARCEL

MAP NO. 2002-1255

EIS

EIS

EIS

EIS

EIS

OR

SQ. FT.

11' SEPTIC SUPPLY EASEMENT

L-5

L-6

L-10

L-7

L-8

L-9

N 17°25'11"E 229.00'

S 42°43'08"E 228.48'

S 73°47'25"W 237.27'

S 12°14'08"W 200.00'

N 51°21'44"W 231.94'

N 43°48'46"E 180.37'

DISTRICT ENGINEER

DATE _____

Arbe Lee

AMBER P. LEE
DB 1519,PG 881
PC F,SLIDE 574-C

DELT WEST
DB 1154,PG 255
PC F,SLIDE 574--C

Harnett County Public Utilities
 Plat Plan PreApproval Only
 NOT FOR CONSTRUCTION

Water is available to this site
via a _____ line located on _____.

Sewer is available to this site
via a _____ line located on _____.

Signature

Date:

