

HTE 04-5-9437

HEALTH COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

17084

OPERATIONS PERMIT

Name: (owner) James Patterson New Installation Septic Tank
 Property Location: SR# 1215 Repairs Nitrification Line
 Subdivision Catie Womack Lot # _____
 Tax ID # _____ Quadrant # _____
 Contractor: Hal Brown Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 200 ft. width of ditches 3 ft. depth of ditches 18 in.

French Drain Required: _____ Linear feet

Date: 5-21-04

Inspected by: Jon WARS
Environmental Health Specialist

PERMIT NO. 20587

