

HTE04-5-9628

H. W. TETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

16999

OPERATIONS PERMIT

Name: (owner) MARIA GAITAN New Installation Septic Tank
 Property Location: SR# HWY 24/27 Repairs Nitrification Line
 Subdivision BURTON ACRES Lot # 1
 Tax ID # _____ Quadrant # _____
 Contractor: MIKE RAY Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 50 ft. width of ditches 3 ft. depth of ditches 18-30 in.

French Drain Required: _____ Linear feet

Date: 8/2/04
 Inspected by: [Signature] RS
 Environmental Health Specialist

PERMIT NO. 20938

