

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual

Well

Spring

Other

Evaluation Method: Auger Boring

Pit

Cut

Type of Wastewater: Sewage

Industrial Process

Mixed

Profile #	.1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1		0-24	LS	FR/LR	10YR 8/6				
		24-48	SC	FR/LR	10YR 6/6				
2		0-24	LS	FR/LR	10YR 8/6				
		24-48	SC	FR/LR	10YR 6/6				
3		0-24	LS	FR/LR	10YR 8/6				
		24-48	SC	FR/LR	10YR 6/6				
4		0-24	LS	FR/LR	10YR 8/6				
		24-48	SC	FR/LR	10YR 6/6				
5		0-24	CS	FR/LR	10YR 8/6				
		24-48	SC	FR/LR	10YR 6/6				
6		0-24	LS	FR/LR	10YR 8/6				
		24-48	SC	FR/LR	10YR 6/6				
7		0-24	LS	FR/LR	10YR 8/6				
		24-48	LC	FR/LR	10YR 6/6				

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	Gravel	LEO
Site LTAR	.5	.25

Other Factors (.1946):

Site Classification (.1948):

Evaluated By:

Others Present:

J. [Signature]
 Holes by Jesse


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1	VFI-VERY FIRM	VS-VERY STICKY
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			
		SICL-SILTY CLAY LOAM		EFI-EXTREMELY FIRM	NP-NON-PLASTIC
					SP-SLIGHTLY STICKY
					P-PLASTIC
					VP-VERY PLASTIC

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



04-5-4001

EXISTING THE HIGHLANDS
@ SHERWOOD FOREST
SUBDIVISION

PHASE I
PHASE II


RT JOHNSON
035/189

SITE PLAN APPROVAL
DISTRICT **RAZOR USE TOWN**

BEDROOMS **3**

U-8-01

043



JAMES MARLOW
588/253

RAYM
6

