

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:

Applicant:

Address:

Date Evaluated: 6/23/04

Property Size:

Proposed Facility: 4800 N. Main St. Design Flow (.1949): 480 gpd

Location of Site:

Property Recorded:

Water Supply: ☐ Public ☐ Individual

☒ Well

[] Spring

☐ Other

Evaluation Method: ~~Auger Boring~~

[] Pit

[] Cut

Type of Wastewater: ☒ Sewage

[] Industrial Process

[] Mixed

[illegible]

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	COW	COW
Site LTR	.2	.8

Other Factors (.1946):

Site Classification (.1948): S

Evaluated By: OT

Others Present: _____

14 x 50' @ 30'


COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1	VFI-VERY FIRM	VS-VERY STICKY
		C-CLAY			
		SC-SANDY CLAY			
				EFI-EXTREMELY FIRM	NP-NON-PLASTIC
					SP-SLIGHTLY STICKY
					P-PLASTIC
					VP-VERY PLASTIC

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



SITE PLAN APPROVAL


DISTRICT RAZOR USE DWMT

#BEDROOMS 4

Date 6/17/04 Russell

Date

Zoning Administrator



Proposed
DWMT

N/F
#4 NEWKIRK-SPRINT
PC D/168-D

Planning Board Certificate
The Harnett County Planning Board hereby
approves this preliminary plat

3-6-01

Date

Chairman

1"=100'