

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: *T. Linn*

Applicant:

Address:

Date Evaluated:

Proposed Facility: *3 BR*
 Location of Site: *Sherwood Road*

Design Flow (.1949): *360*

Property Size:

Water Supply: Public Individual Well

Property Recorded:

Evaluation Method: Auger Boring Pit

Spring

Other

Type of Wastewater: Sewage Industrial Process

Cut

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1		0-18	LS	FR/GM	10YR 8/1				
		18-48	SC	FR/L	10YR 6/1	48			
2		0-30	LS	FR/L	10YR 8/2				
		30-48	SC	FR/L	10YR 6/1	48			
3		0-18	LS	FR/L	10YR 8/1				
		18-48	SC	FR/L	10YR 6/1				
4		0-12	LS	FR/L	10YR 8/1				
		12-48	SC	FR/L	10YR 6/1	48			
5		0-18	LS	FR/L	10YR 8/1				
		18-48	SC	FR/L	10YR 6/1	48			
6		0-10	LS	FR/L	10YR 8/1				
		10-48	SC	FR/L	10YR 6/1	48			
7		0-18	LS	FR/L	10YR 8/1				
		18-48	SC	FR/L	10YR 6/1	48			

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	<i>Gravel</i>	<i>LPR</i>
Site LTAR	<i>.6</i>	<i>.3</i>

Other Factors (.1946): _____
 Site Classification (.1948): _____
 Evaluated By: *J. Linn*
 Others Present: *P.H.s by Jason*


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			


STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



1=50



SITE PLAN APPROVAL
 DISTRICT RAZOR USE DWMH
 #BEDROOMS 3 w/ Att. Gar.
 Date 5/30/04 Prinwell
 Zoning Administrator