

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:


Location of Site:

Property Recorded:

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

Profile #	1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/Texture	1941 Consistence Mineralogy	1942 Soil Wetness/Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr. Horiz	
		0-36	SL	FR/LR					
		36-48	SCL	FR/LR		4/			.6
		0-30	SL	FR/LR					
		30-42	SCL	FR/LR					.4
		42-48	SL	S F2		4/			.4
		0-24	SL	FR/LR					
		24-36	SCL	FR/LR					.4
		36-48	SL	S F2		4/			.4
		0-24	SL	FR/LR					
		24-36	SCL	FR/LR		4/			.4
		36-48	SL	S F2					.4
		0-24	SL	FR/LR					
		24-36	SCL	FR/LR		4/			.4
		36-48	SL	FR/LR					.4
		0-30	SL	FR/LR		4/			.4
		30-48	SCL	FR/LR					.4

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	Gravel	HOA
Site LTAR	.4	.2

Other Factors (.1946): _____
 Site Classification (.1948): _____
 Evaluated By: 
 Others Present:


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



1267/41

2
31-1104
PG. 311

LOT 3
MAP # 98-221
YARBOROUGH
1385/928

LOT 4
MAP # 98-221
YARBOROUGH
1273/249

COX
1167/928

LOT 3
3.39 AC.

LOT 4
M.B. 1 PG. 29
WOMACK
168/569

FURTIS RANDALL O'QUINN
300, PG. 320 HARNETT COUNTY

IOD

SITE PLAN APPROVAL
 DISTRICT PA20R USE SWMH
 #BEDROOMS 2
115-04
 ZONING ADMINISTRATOR [Signature]

