

# IMPROVEMENT PERMIT

21436

HTE 04-500105238

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) SABRINA McLEAN  New Installation  Septic Tank  
Property Location: SR# 2035 STOCKYARD RD  Repairs  Nitrification Line

Subdivision STOCKYARD ESTATES Lot # 59

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 4 Lot Size: .67ac

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 100 ft.

**Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.**

Type of system:  Conventional  Other 25% REDUCTION ~~SEWER~~ SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons


Subsurface Drainage Field No. of exact length width of depth of  
ditches 6 of each ditch 70 ft. ditches 3 ft. ditches 18-28 in.

French Drain Required: \_\_\_\_\_ Linear feet

Date: 12/17/04

**This permit is subject to revocation if site plans or intended use change.**

Signed: [Signature] RS (OLIVER TOLKSOOF)  
Environmental Health Specialist



\* MAINTAIN ALL SETBACKS  
\* CALL WITH ANY QUESTIONS  
PRIOR TO INSTALLATION

HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 21436. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

SABRINA McLEAN Name 914-2669 Telephone #

PO Box 214 WILMINGTON NC 27546 Address

2035 Property Location SR# STOCKYARD RD Road Name

STOCKYARD RD EST. Subdivision 59 Lot # 4 # Bedrooms Proposed .67 Lot Size

**TYPE OF SYSTEM**

- New Installation [ ] Repair  Septic Tank  Nitrification Lines  
[ ] Conventional  Other 25% REDUCTION SYSTEM  
[ ] Basement [ ] With Plumbing [ ] Without Plumbing

Water Supply: [ ] Well  Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber \_\_\_\_\_ gal

**NITRIFICATION FIELD SPECIFICATIONS**

Number of fields 1 # of lines per field 6 Length of lines 70 Ft.

Width of ditches 3 ft. Depth of ditches 18-28 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

[Signature] Signature of Authorized Agent for Harnett County 12/17/04 Date