H. NETT COUNTY HEALTH DEPAI IENT 17666

HTE # 05-500-12614R ENVIRONMENTAL HEALTH SECTION

OPERATIONS PERMIT

Name: (owner) Pine Grove Dev. Corp ☒ New Installation ☒ Septic Tank ☐ Repair

Property Location: SR# 1141 ☒ Nitrification Line ☐ Expansion

Subdivision Cherokee Ridge Lot # 16 Tax ID # _____ Quadrant # _____

Contractor: Ted Brown Registration # _____

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☐ Conventional ☒ Other 25% Reduction System Infiltrator Quick 4

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field | No. of ditches 1 | exact length of each ditch 140 ft. | width of ditches 3 ft. | depth of ditches 18-24 in.

French Drain Required: _____ Linear feet 9 chamber Date: 09-01-05

PERMIT NO. [redacted] 22710 Inspected by: JA WARS