

# SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER


APPLICANT NAME

Timberline Lot 4

DATE

7/9/01

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-15	0-16	0-16	0-8										
Texture Group	.1941(A)(1)	SH/LS	LS	LS	LS										
Consistence	.1941	VFR	VFR	VFR	VFR										
Structure	.1941(A)(2)	F	C	G	S										
Mineralogy	.1941(A)(3)	NS/ND	NS/ND	NS/ND	NS/ND										
HORIZON 2 DEPTH		15-34	14-37	16-37	8-38										
Texture Group	.1941(A)(1)	SL	SL	SL	SL										
Consistence	.1941	FR	FR	FR	FR										
Structure	.1941(A)(2)	SBK	SBK	SBK	SBK										
Mineralogy	.1941(A)(3)	SS/SP	SS/SP	SS/SP	SS/SP										
HORIZON 3 DEPTH		34"*	37"	37"*	38"										
Texture Group	.1941(A)(1)	SC/C	C/PM	C/PM	C/PM										
Consistence	.1941	FR	FR												
Structure	.1941(A)(2)	ABK/PL	ABK/PL												
Mineralogy	.1941(A)(3)	SS/SP	SS/SP												
HORIZON 4 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
SOIL WETNESS	.1942	34"	37"	37"	X										
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/1958														
CLASSIFICATION	.1948	PS	PS	R	R										
LONG TERM ACCEPTANCE RATE	.1955	3	3	3	3										




THOMAS H. MORRISON  
 DB 1290, PG 58  
 MAP NO. 98-341

DONALD E. LANIER  
 DB 1038, PG 333  
 MAP NO. 98-341

1.50 AC.  
 + 0.04 AC.  
**1.54 AC. TOTAL**

- COURSE
- L-1
  - L-2
  - L-3
  - L-4
  - L-5
  - L-6
  - L-7



0-12W  
 12-325CL  
 32-36-2

#7 0-1265  
 12-305CL  
 32-42-2  
 LTPR .3

#4 0-1265  
 12-305CL  
 32-425CL  
 LTPR .3

0-12W  
 12-245CL  
 24-326CL  
 32-42-2  
 LTPR .25



LTPR .4

N.C. HWY 27

Front Best


0-12W  
 12-30-5CL  
 32-36-2  
 LTPR .3

Map Legend

-  Provisionally Suitable Soils
-  Unsuitable Soils

SURVEY FOR:

Fence



5x80  
18"  
MAT