

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner: 06.500 15421

Applicant:

Date Evaluated: 8-8-06

Address:

Property Size: 100 x 247 x 100 x 247

Proposed Facility: m1

Design Flow (.1949): 48

Property Recorded: m

Location of Site: 1295

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY (1941)		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1944 Saprot Class	1944 Restr. Horiz.	
1	3%	0-12	GR SL	VLR S2					5
		18-30	SBK SCL	FR S2					
		30-40	GR SL	VLR S2		42			
2	3%	0-20	GR SL	VLR S2				5	
		20-43	SBK SCL	FR S2		48			
3	3%	0-20	GR SL	VLR S2				5	
		20-48	SBK SCL	FR S2		48			
4	3%	0-43	GR SL	VLR S2				6	
						48			
5	3%	0-78	GR SL	VLR S2				6	
						42			

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	Grout	LPV
Site LTAR	.5	.25

720 LP 705 LF

Other Factors (.1946): _____
 Site Classification (.1948): _____
 Evaluated By: *[Signature]*
 Others Present: _____