

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Choo Choo Home PROPERTY LOCATION: N124
 NEW REPAIR EXPANSION SUBDIVISION: Heritage Village LOT # G-30
 Type of Structure: MH-28x76-3BR Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: Gravel
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: Meet onsite maintain ALL set BACK, make sure that rear property corners are clearly staked along with G-24 EASEMENT AREA. STAY OUT PLUMBING SHALLOW No expiration

Authorized State Agent: Joe Lutz RL Date: 03-19-07 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Choo Choo Home PROPERTY LOCATION: N124
 SUBDIVISION: Heritage Village LOT # G-30
 Facility Type: MH 28x76-3BR New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** Gravel (Initial) Wastewater Flow: _____ GPD
 (See note below, if applicable) 290 LF 1 LPP (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 1x240 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 18max inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to +/-1/4" in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
 _____ inches above pipe
 _____ inches total

**If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.


Authorized State Agent: Joe Lutz RL Date: 03-19-07 SEE ATTACHED SITE SKETCH
 Construction Authorization Expiration Date: 03-19-2012

HTE# 0650015595R

Permit # 23805

Harnett County Department of Public Health Site Sketch

ISSUED TO: Choo Choo Homes PROPERTY LOCATOR: NC24
SUBDIVISION: Heritage Village LOT # G-30
Authorized State Agent: J. L. [Signature] Date: 3.19.07



Meet onsite - STUB out Plumbing shallow, At ground level or higher - maintain ALL set Backs - make sure that rear property line is clearly marked & that G-24 Easement is clearly marked.