

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner: 06-500 16091

Applicant:

Address:

Date Evaluated: 11-29-01

Proposed Facility: MH

Design Flow (.1949): 360

Property Size: .68 ac

Location of Site: 1129

Property Recorded:

Water Supply: Public Individual Well

Spring Other

Evaluation Method: Auger Boring Pit

Cut

Type of Wastewater: Sewage Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Witness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	S 5%	0-8	GA SL	VFA 1F					.25
		8-36	SAK XE	FZ 1F					
		36-	PA						
2	S	0-8	GA SL	VFA 1F					.25
		8-20	SAK SL	FZ 1F					
		20-1	PA						
3	S	0-8	GA SL	VFA 1F					.25
		8-20	SAK SL	FZ 1F					
		20-	PA						
6	S	0-12	GA SL	VFA 1F					.25
		12-26	SAK SL	FZ 1F					
		26-	PA						
	S	0-8	GA SL	VFA 1F					.25
		8-20	SAK SL	FZ 1F					
		20-	PA						

Description	Initial System	Repair System
Available Space (.1945)	-	-
System Type(s)	25%	UP
Site LTAR	.25	.18

Other Factors (.1946):
Site Classification (.1948): P1
Evaluated By: [Signature]
Others Present:

1x 360 = 1 25% of MH system