

HTE# 07-50017189

## Harnett County Department of Public Health

23838

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Clyde PattersonPROPERTY LOCATION: 1211  
SUBDIVISION DR TLOT # 2BNEW  REPAIR  EXPANSION Type of Structure: MH 28x62 3BR

Site Improvements required prior to Construction Authorization Issuance:

Proposed Wastewater System Type: Pump to 25 ft. Redaction systemProjected Daily Flow: 360 GPDNumber of bedrooms: 3 Number of Occupants: 6 maxBasement  Yes  NoPump Required:  Yes  No  May be required based on final location and elevations of facilitiesType of Water Supply:  Community  Public  Well Distance from well 50 feet

Permit valid for:

 Five years No expirationPermit conditions: Meet on site MAINTAIN ALL SETBACKS MUST BEING in 8 to 12" 1 Approved Cover STUB out plumbing where shownAuthorized State Agent: J. L. AtchDate: 4-11-07

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Clyde PattersonPROPERTY LOCATION: 1211SUBDIVISION DR TLOT # 2BFacility Type: MH 28x62 3BR  New  Expansion  RepairBasement?  Yes  No Basement Fixtures?  Yes  NoType of Wastewater System\*\* Pump to 25 ft. Red. syst. (Initial) Wastewater Flow: 360 GPD(See note below, if applicable )Pretreat to outlet shall be (Repair)ConventionalSeptic Tank Size 1000 gallons  
Pump Tank Size 1000 gallonsExact length of each trench 1 X 225 feetTrench Spacing: 9 Feet on Center

Trenches shall be installed on contour at a

Soil Cover: 6 inchesMaximum Trench Depth of: 12 inches

(Maximum soil cover shall not exceed

(Trench bottoms shall be level to +/- 1/4" in all directions)

36" above the trench bottom)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM

inches below pipe

Conditions: \_\_\_\_\_

Aggregate Depth: \_\_\_\_\_ inches above pipe

inches total

\*\*If applicable:

I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_

Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: J. L. Atch

SEE ATTACHED SITE SKETCH

Date: 04-11-07Construction Authorization Expiration Date: 04-11-2012

HTE# 07-50017189

Permit # 23838

Harnett County Department of Public Health  
Site Sketch


ISSUED TO: Clyde Patterson

PROPERTY LOCATON: 1211  
SUBDIVISION DRT

LOT # 2B

Authorized State Agent: J. W. R.

Date: 04-11-07



Meet onsite for Final Layout

Supply Line must be installed as shown

Install 1x2x5 @ 25% elevation soffit at 12"

Must bring in 8 to 12" of approved cover