

SR#1211-60' R/W
PAVED

PAVED

N21°58'44"E 179.73'

N21°58'44"E 130.00'

NOTE!
OVERHEAD ELECTRIC
OVERHEAD P/W.
ALONG

~~0.85 AC. IN R/M
0.09 AC. NET
0.76~~

JESSE ROAD
SR#1212-60 P/W
HAYDEN

SITE PLAN APPROVAL

DISTRICT

#BEDROOMS

OR USE DWMH

ZONING ADMINISTRATOR

1.24 AC. IN R/M
-0.05 AC. NET
1.19 AC. NET

69

SOUTHEASTEN SOIL & ENVIRONMENTAL ASSOC, INC.

PROPOSED SUBSURFACE WASTE DISPOSAL SYSTEM DETAIL SHEET

SUBDIVISION DRT

LOT 2B

INITIAL SYSTEM pump to APPROVED 25% reduction

REPAIR peat / conventional

DISTRIBUTION pump to D-box (series)

DISTRIBUTION series

BENCHMARK 100.0

LOCATION rear corner 2B/2C

NO. BEDROOMS 3

proposed LTAR = 0.4 gpd / ft²

<u>LINE</u>	<u>FLAG COLOR</u>	<u>ELEVATION</u>	<u>ACTUAL LENGTH</u>
1	0	100.67	35'
2	Y	100.33	50'
3	0	100.17	70'
4A	Y	99.84	70'
			<u>225'</u>
4B	Y	99.84	50'
5	0	99.67	140'
6	Y	99.34	110'
			<u>300'</u>

Initial {

BY McCAUSA

DATE 3/12/07

Repair peat conv 21" to Cr2