

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Gayle J. Hurd
PROPERTY LOCATION: Freedom Lane - off of Jesse Rd
SUBDIVISION: _____ LOT # 13
Type of Structure: mit 4BR 28x80
Proposed Wastewater System Type: Pump to 25% Reduction system
Projected Daily Flow: 480 GPD
Number of bedrooms: 4 Number of Occupants: 8 max
Basement: [] Yes [x] No
Pump Required: [x] Yes [] No [] May be required based on final location and elevations of facilities
Type of Water Supply: [] Community [x] Public [x] Well Distance from well 100 feet
Permit valid for: [x] Five years [] No expiration
Permit conditions: meet on site before installing maintain all set back, keep well 100 feet from any part of the septic system

Authorized State Agent: [Signature] Date: 5-31-07 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Gayle J. Hurd
PROPERTY LOCATION: Freedom Lane
SUBDIVISION: _____ LOT # 13
Facility Type: MH 4BR 28x80 [x] New [] Expansion [] Repair
Basement? [] Yes [x] No Basement Fixtures? [] Yes [x] No
Type of Wastewater System** Pump to 25% Red. sys. (Initial) Wastewater Flow: 480 GPD
(See note below, if applicable) 670 LF of LPP (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 1x410 feet Trench Spacing: 9 Feet on Center
Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
Maximum Trench Depth of: 18 max inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe _____ inches above pipe _____ inches total
Conditions: _____

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: [Signature] Date: 5-31-07 SEE ATTACHED SITE SKETCH
Construction Authorization Expiration Date: 5-31-2012

HTE# 07-50017530

Permit # 23931

Harnett County Department of Public Health Site Sketch

ISSUED TO: Gayle J. Hurd

PROPERTY LOCATION: Freedom Lane
SUBDIVISION: _____

LOT # 13
16.14 AC

Authorized State Agent: Joe Warr

Date: 5-31-07

Meet on site for Final Layout
Maintain All set Backs
Install 1x410 of 25% Reduction system
At 18" max Ditch Depth
Keep well 100' from any syptic system

